

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 15-12-2023

It is certified that an inspection team headed by Dr. Usha Gungyal From Health Department inspected the school P.N.F. Public School on 11-12-2023 checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid till 10-12-2024

Signature with seal: Deputy

Chief Deputy Officer
Pithoragarh (Uttarakhand)

Name: Dr. Usha Gungyal

Designation: Deputy CMO

To

P.N.F. Public School
Jakh Puram Road, Aincholi,
Pithoragarh.



कार्यालय अधिशासी अभियन्ता उत्तराखण्ड जल संस्थान, पिथौरागढ़

पत्रांक 1489/ जल परीक्षण / 80 दिनांक / 8/06/2023

सेवा में,

प्रधानाचार्य,
पी0एन0एफ0 पब्लिक स्कूल जाख पुरान रोड ऐंचोली
पिथौरागढ़।

विषय—पेयजल नमूने के जाँच कराने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके पत्र दिनांक 07.06.2023 द्वारा पेयजल परीक्षण हेतु उपलब्ध कराये गये वॉटर सैम्पल का परीक्षण के उपरान्त रिपोर्ट संलग्न कर प्रेषित की जा रही है।
संलग्नक— उपरोक्तानुसार।

भवदीय

(सुरेश चन्द्र जोशी)
अधिशासी अभियन्ता (प्र०)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan Pithoragarh

Ph (O): दूरभाष (काठ) 05964(225237)
E-mail: eepitujs@gmail.com



TC-10070

Test Report ID: 751/UJS/DLWQTML/2023-24


Dated: 09/06/2023

TEST REPORT

Name and Address of Organization/ Customer	Principal, P.N.F Public School Jakh Puran road Aincholi Pithoragarh.		
Product Description	Drinking Water	Sample Description	One Water Sample Collected From P.N.F Public School Jakh Puran road Aincholi Pithoragarh.
Reference Sample Identification:	DLWQTML/UJS/PN-01		Date of Start of Analysis:08/06/2023 Date of End of Analysis :09/06/2023
Date and Time of Sample Received:07/06/2023 & 12:20PM	Sample Collected by:		Customer

SN	Parameters	Results	Acceptable Limit (BIS)	Permissible Limit (BIS)	Std. Test Method
1.	pH at 25°C	6.84	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Turbidity, NTU Max	Less Than 0.5	1	5	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Total Dissolved Solids (TDS), mg/L Max	160	500	2000	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L Max	100	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L Max	138	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Colour, Hazen Max	Less than 1	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
7.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
8.	Calcium (as Ca), mg/L Max	28	75	200	IS 3025(Part 40):1991(RA 2019) EDTA Titrimetric Method
9.	Magnesium (as Mg), mg/L Max	17	30	100	APHA 3500-Mg (B): 2017 Calculation method
10.	Chloride, mg/l Max	Less Than 5.0	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


(E.R. SURESH JOSHI)
(TECHNICAL MANAGER)/
Lab In-Charge

-End of Report-

1. The results listed refer only to tested sample and applicable parameters and sample submitted by customer end for above parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The result apply to the sample as received



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Pithoragarh**

Ph (O): दूरभाष (काठ) 05964(225237)

E-mail: eeptujs@gmail.com

Test Report ID: 751A/UJS/DLWQTML/2023-24

Dated: 09/06/2023

TEST REPORT

Name and Address of Organization/ Customer		Principal, P.N.F Public School Jakh Puran road Aincholi Pithoragarh.			
Product Description		Drinking Water	Sample Description	One Water Sample Collected From P.N.F Public School Jakh Puran road Aincholi Pithoragarh.	
Reference Sample Identification:		DLWQTML/UJS/PN-01		Date of Start of Analysis:08/06/2023	
				Date of End of Analysis :09/06/2023	
Date and Time of Sample Received:07/06/2023 & 12:20PM			Sample Collected by:		Customer
SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)	Std. Test Method
1.	Residual Free Chlorine, mg/L	ND	0.2	1.00	APHA 23rd Ed.-4500-CL ⁻ G
Bacteriological Parameters					
2.	Total Coliform, MPN /100ML	Absent	Absent	Absent	Apha23rd F:d-9223-B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

(ER. SURESH JOSHI)
(TECHNICAL MANAGER)/
Lab In-Charge

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with Customer.
4. The result apply to the sample as received